

**CALIFORNIA REGIONAL WATER QUALITY CONTROL BOARD
LOS ANGELES REGION**

101 CENTRE PLAZA DRIVE
MONTEREY PARK, CA 91754-2156
(213) 266-7500
FAX: (213) 266-7600



SFUND RECORDS CTR
32128

May 16, 1995

Joe P. Kwan
TRW INC.
1900 Richmond Road
Cleveland, Ohio 44124

WELL INVESTIGATION PROGRAM - WORK PLAN, TRW/MONADNOCK, 18301 ARENTH AVE., CITY OF INDUSTRY (FILE NO. 105.0181/CAO088-057)

We are in receipt of the "Ground water Treatment System Feasibility Study Work Plan", dated March 1995, prepared by your consultant, IDEA ENVIRONMENTAL ASSOCIATES INC. This report presents a proposal for the installation of two ground water monitoring wells and a pilot test to evaluate the feasibility of ground water cleanup at the site.

Upon review of the subject work plan, we have no objections to implementation of the work as proposed. Unless you plan to operate the proposed ground water remediation at unusually high rates of production and considering the anticipated occurrence of the most heavily contaminated ground water in the upper few feet of the saturated zone, you may wish to delay installation of proposed MW-13, and the pump test, and commence remediation from MW-2 at the usual low rates of production. The optimum rate of production may be determined by varying pump rates during the initial cleanup period. If the rates are unsatisfactory, MW-13 can be installed and tested.

Please contact the undersigned at (213)266-7531 if you have any questions.

A handwritten signature in black ink, appearing to read "Eric Nupen", is written over a horizontal line.

ERIC NUPEN, R.G.
Senior Engineering Geologist

cc: ✓ Phillip Ramsey, USEPA, Region, San Francisco
Dennis Dickerson, Cal-EPA, DTSC, Region 3
Carol Williams, San Gabriel Valley Watermaster
Debbie Takashima, TRW Inc., Redondo Beach
Steve Mulligan, IDEA, Fountain Valley